


23<sup>rd</sup> April, 1998



Harmonious Blend Building Corporation Pty. Ltd.  
Wray Crescent,  
MOUNT EVELYN VIC 3796

**RE: LOT 4, 92 BIRMINGHAM RD. MT. EVELYN**

Thank you for your letter dated 21/4/98.

We acknowledge the supply of D pull timber handles to be covered by the \$90.00 already paid.

The use of K.D. H.W. in lieu of Meranti will be suitable.

The cost of the extra 1.05 sq mts of bench to the island bench in the kitchen seems to be excessive. The total bench space previously to be supplied works out at approximately 5.16 sq mts. At the rate of \$340.95 per square mtr quoted for the extra 1.05 sq mts requested, would give an allowance of \$1759.31 for bench top. If this is the case we would be pleased to receive a credit for this amount, less \$50.00 admin and \$80.00 variation. We would then supply our own bench tops. This would be a credit of \$1629.31. Please advise.

The works carried out to this point I must say is excellent in general. However, I do have some concern with the installation of the windows. In some cases the sash is hard up against the timber on one side and a large gap on the other side, which makes the window quite hard to open and shut. There may be some adjustment still required that I am not aware of.

Could you please advise what type of insulation to the ceilings is going to be used to meet the R.2.5 requirement, and the walls at R.1.5.

Thankyou, I look forward to your reply.

Yours sincerely,

A handwritten signature in cursive script, appearing to read "Neil &amp; Marcia Meyer".

**NEIL & MARCIA MEYER**